



QMO	URGENZA	Pol.	Ib	Kc	R	S	I	N	In	quad.	corrente	diff. - I _{dn}	tipo	pl	In	In
		kw	A	Ku	1	2	3	4	A		A	kn	relé	KA	A	Contattore
	TERRA															
NO7Y-K 3x1.5	CIRCUITO LUCI CL1								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL2								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL3								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL4								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL5								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL6								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL7								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL9								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL11								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL12								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL8 corridoio								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL10 corridoio								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL13 corridoio								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO OROLOGIO PRESENZE								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO LUCI CL 14 EMERGENZA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO ALIM. VIDEOCITOFONO								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO SPLIT 1								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO SPLIT 2								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO SPLIT 3								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO SPLIT 4								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
NO7Y-K 3x1.5	CIRCUITO SPLIT 5								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
EGZOR SG25	A QUADRO COMANDI (cdz)								2x16	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		
	CIRCUITO RISERVA								2x10	C	0,03		<input checked="" type="checkbox"/>	6,0		