



CANO	UTENZA	Pot. kW	Ib A	Ic KA	R	S	T	N	In Approvazione	Cond.	corrente diff. - I <sub>Δn</sub>	tipo test	Pt KA	In Fusibile	In Condizione
	TERRA								A		A				
N07V-K 3x1,5	CIRCUITO LUCI CL1				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL2				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL3				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL4				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL5				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL6				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL7				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL9 corridoio				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL11 corridoio				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x2,5	CIRCUITO OROLOGIO PRESENZE				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO LUCI CL 8 EMERGENZA				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO ALIM. VIDEOTELEFONO				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	CIRCUITO RISERVA				•	•	•	•	2x10	C	0,03	☒	6,0		
	SEZIONE FANCOIL				•	•	•	•	4x25	D			6,0		
	OROLOGIO SETTIMANALE A CAVALIERI				•	•	•	•	2x10						
	TELERUTTORE ACCENSIONE FANCOIL				•	•	•	•	4x63						
					•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO FANCOIL 1				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO FANCOIL 2				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO FANCOIL 3				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO FANCOIL 4				•	•	•	•	2x10	C	0,03	☒	6,0		
N07V-K 3x1,5	CIRCUITO FANCOIL 5				•	•	•	•	2x10	C	0,03	☒	6,0		